

Table 1. 2011 Detected REGULATED Contaminants									
Contaminant	MCL Violation If	Units	MCLG	East Jefferson		West Jefferson		Violation Yes / No	Source of Contaminant
				Highest Month		Highest Month			
Total Coliform Bacteria (% of monthly samples containing coliform bacteria)	>5% of monthly samples containing coliform bacteria	%	0	1.6		0.8		No	An indicator which is naturally present in the environment and not in itself harmful.
Contaminant	MCL Violation If	Units	MCLG	East Jefferson		West Jefferson		Violation Yes / No	Source of Contaminant
				Max Value	Min %	Max Value	Min %		
Turbidity (lowest monthly % of samples at or below 0.3 NTU and the highest single sample result)	TT < 95 % at or below 0.3 NTU or a single sample > 1 NTU	% NTU	NA NA	NA 0.59	99.4 NA	NA 0.3	100 NA	No	Naturally present particulate matter derived from soil runoff which as an indicator and is not in itself harmful.
Contaminant	MCL Violation If	Units	MCLG	East Jefferson		West Jefferson		Violation Yes / No	Source of Contaminant
				Range	Max	Range	Max		
Arsenic	> 10 (Annual Average)	ppb	0	0.5 - 1.8	1.1	0.4 - 1.4	1.0	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Atrazine	> 3 (Annual Average)	ppb	3	BD - 0.2	0.1	BD - 0.1	0.1	No	Runoff from herbicide used on row crops, primarily in the corn belt
Barium	>2000 (Annual Average)	ppb	2000	55 - 74	65	55 - 74	65	No	Discharges of drilling wastes & metal refineries; erosion of natural deposits
Carbon Tetrachloride	>5 (Annual Average)	ppb	0	na	0.8	na	0.7	No	Discharge from chemical plants and other industrial activities
Di(2-ethylhexyl)phthalate	>6 (Annual Average)	ppb	0	na	1.5	na	1.5	No	Discharge from rubber and chemical factories
Fluoride	> 4 (Annual Average)	ppm	4	0.6	0.6	0.6	0.6	No	Erosion of natural deposits and water additive promoting strong teeth
Mercury(inorganic)	> 2 (Annual Average)	ppb	2	BD	BD	BD - 0.1	0.04	No	Erosion of natural deposits; Discharge from refineries and factories
Nitrate (as nitrogen)	> 10 (Any time)	ppm	10	0.5 -2.3	2.3	0.6 - 2.3	2.3	No	Runoff from fertilizer use and erosion of natural deposits
Total Chlorine Residual	> 4 (Annual Average)	ppm	4	0.1- 2.5	1.4	0.1 - 2.9	1.7	No	Required by EPA for Disinfection
TTHMs (Total trihalomethanes)	> 80 (Annual Average)	ppb	0	25 - 81	52	35 - 123	62	No	By-product of drinking water disinfection using chlorine
THAAs (Total haloacetic acids)	> 60 (Annual Average)	ppb	0	10 - 45	24	3 - 98	33	No	By-product of drinking water disinfection using chlorine
Uranium	> 30 (Annual Average)	ppb	0	na	1	na	1	No	Erosion of natural deposits
Contaminant	MCL Violation If	Units	MCLG	East Jefferson		West Jefferson		Violation Yes / No	Source of Contaminant
				Range	Min	Range	Min		
Total Organic Carbon (TOC) (ratio of the percentage of the TOC removed divided by the percentage TOC required to be removed)	TT ratio < 1 (Annual Average)	ratio	NA	0.8 - 2.1	1.3	0.9 - 1.5	1.2	No	Harmless natural organic material which forms chlorinated by-products (TTHMs & THAAs) during disinfection
Contaminant	Action Level (AL) Exceeded If	Units	MCLG	East Jefferson		West Jefferson		Violation Yes / No	Source of Contaminant
				90th Pct	# > AL	90th Pct	# > AL		
Copper (2010 last required monitoring)	> 1.3	ppm	1.3	0.4	0	0.4	0	No	Household plumbing corrosion and erosion of natural deposits
Lead (2010 last required monitoring)	> 15	ppb	0	6	1	3	0	No	Corrosion of household plumbing

">" = Greater than ; "<" = Less than ; **AL** = Action Level - The concentration of the 90th percentile of analysis results, when exceeded, triggers treatment or other requirements which a water system must follow (there is no MCL or MCLG for these contaminants) ; **Annual Ave** = annual running average determined from the average of the sample results over the previous 12 months ; **BD** = Below Detection of the analytical method - the substance was not found ; **Max** = Maximum observed value or maximum annual running average (Annual Ave) used for regulatory compliance ; **MCL** = Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water which are set as close to the MCLGs as feasible using the best available treatment technology ; **MCLG** = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health MCLGs allow for a margin of safety; **na** = not applicable ; **NTU** = Nephelometric Turbidity Units ; **pCi/L** = picocuries per liter (a measure of radioactivity); **50 pCi/L** = 4 milliroentgen equivalent man/year (4 mrem/yr) ; **ppm** = parts per million or milligrams per liter (mg/L) -equivalent to 1 minute in 2 years or \$0.01 in \$10,000; **ppb** = parts per billion, or micrograms per liter (ug/L) - equivalent to 1 minute in 2,000 years or \$0.01 in \$10 million ; **Range** = Range of all sample analysis results observed ; **TT** = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water ; 90th Pct = 90th percentile of sample analysis results # > AL = number of samples greater than the action level: